





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE - EXAMINATION		Certificate N°
In accordance with module B of Directive 2014/90/EU on Marine Equipment		18/SP/4453-0-REV 0
Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia)
Concerned Equipment : Portable Fire Extinguishers (Powder Stored Pressure)		
Type : PP 1 HD		
Technical: PED Cert n°03/SP/143 from APRAGAZ and Laboratory EN3-7 test report from CTDM n°LEE18032		
Capacity : 1 kg		Fire Rating: 8A/34B
Set pressure : max. 16 bar (+60°C)		Test Pressure: 27 bar
Service temperature range : min. -20°C / max. +60°C		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by NOBO n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 12/12/2023.</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the above mentioned Directive, certifies that the types of equipment defined here above are conform to the relevant requirements of the pertinent EN 3 standards in force and the Marine Equipment Directive 2014/90/EU (as amended) on basis of the documentation and samples supplied for review and approval.</p>		
Date of first issue : 13/12/2018	Name : Ch. Leplat	Position General Manager
Notified body identification number :	0029	Signature
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P4575/000	