





Chaussée de Vilvorde, 156  
Vilvoordsesteenweg 156  
B-1120 Bruxelles/Brussel  
Tel.: 32 (0)2 264 03 60  
Fax: 32 (0)2 268 89 58  
http://www.apragaz.com  
info@apragaz.com



<b>NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE</b>  <b>In accordance with module B of the Marine Equipment Directive 2014/90/EU as amended</b>		<b>Certificate N°</b>  <b>18/SP/4273-0-Rev 1</b>
<b>Manufacturer</b>	<b>Name</b>  <b>Industrias AUCA S.L.</b>	<b>Pol. Ind. Alqueria de Mina</b>  <b>Calle Tappissers, 3</b>  <b>SP - 46200 Paiporta (Valencia)</b>  <b>SPAIN</b>
	<b>Address</b>	
<p><b>Concerned Equipment:</b> Item n° A.1/3.2 : Portable Stored Pressure Fire Extinguisher</p> <p><b>Type :</b> PPE- 2</p> <p><b>Nominal charge:</b> 2 l. Water with additive (premix)</p> <p><b>Fire ratings:</b> 5A – 55B – 5F</p> <p><b>Temperature range:</b> min.+5°C / max. +60°C</p> <p><b>EN3-7 Test report :</b> APRAGAZ n° EN 11808</p>		
<p>The manufacturer is allowed to affix the marine CE mark  followed with our notified body identification n° 0029 to the approved equipment in the conditions described in article 11 of the Directive, only if the requirements stated in Module D are fully complied with.</p> <p style="text-align: center;"><b>The approval is valid until 04/02/2023</b></p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 96/98/EC, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3 standard and the Marine Equipment Directive 2014/90 EU as amended on basis of the documentation and samples supplied for review and approval.</p>		
Approval Date : <b>05/02/2018</b>	Name : <b>Ch. Leplat</b>	Positiior <b>General Manager</b>
Notified body identification number :	<b>0029</b>	Signature
Notified body stamp :	<b>APRAGAZ</b> <b>Belgium</b> <b>Inspecting</b> <b>Authority</b>	
Notified body reference :	<b>P4575/015</b>	