




Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE EXAMINATION		Certificate N°
In accordance with module B of Directive 2014/90/EU on Marine Equipment		15/SP/3572-1-REV 0
Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN
Concerned Equipment: Item n° MED/3.2 : Portable Stored Pressure Fire Extinguisher		
Type : PP 3 P		
Nominal charge: 3 kg. Powder ABC 40		
Fire ratings: 13A – 89B - C		
Temperature range: min.-20°C / max. +60°C		
EN3-7 Test certificate : AFNOR n° EP3 157 627 A0		
<p>The manufacturer is allowed to affix the marine CE mark  followed by the notified body n° and the year of manufacturing (four digits) to approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 01/03/2025</p>		
<p>APRAGAZ, acting within the scope of its notification for the Directive 2014/90/EU, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 in force and to the Marine Equipment Directive 2014/90/EU as amended, on base of the documentation and samples supplied for review and approbation.</p>		
Date : 18/03/2020	Name : B.Neve	Position General Manager
Notified body identification number :	0029	Signature 
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P4567/000	