





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE EXAMINATION In accordance with module B of Directive 2014/90/EU on Marine Equipment		Certificate N° 20/SP/4638-0-REV 0
Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN
<p>Concerned Equipment: Item n° MED/3.2 : Portable Stored Pressure Fire Extinguisher</p> <p>Type : PP6PS / PP9HDI</p> <p>Nominal charge:</p> <ul style="list-style-type: none"> • 6 kg. Powder PP6PS: ABC • 9 kg. Powder PP9HDI: ABC <p>Fire ratings: PP6PS: 27A – 183B – C / PP9HDI: 34A – 233B – C</p> <p>Temperature range: min.-20°C / max. +60°C</p> <p>EN3-7 Test certificate : AENOR PP6PS Report n° 06/18 & Certificate n° 012/002933 / AENOR PP9HDI Report nr 07/18 & Certificate n° 012/003119</p>		
<p>The manufacturer is allowed to affix the marine CE mark  followed by the notified body n° and the year of manufacturing to approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 03/05/2025</p>		
<p>APRAGAZ, acting within the scope of its notification for the Directive 2014/90/EU, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 in force and to the Marine Equipment Directive 2014/90/EU as amended, on base of the documentation and samples supplied for review and approbation.</p>		
Date : 04/05/2020	Name : B.NEVE	Position General Manager
Notified body identification number :	0029	Signature 
Notified body :	APRAGAZ VZW / ASBL	
Notified body reference :	4567P000	