





Chaussée de Vilvorde, 156  
Vilvoordsesteenweg 156  
B-1120 Bruxelles/Brussel  
Tel.: 32 (0)2 264 03 60  
Fax: 32 (0)2 268 89 58  
http://www.apragaz.com  
info@apragaz.com



<b>EC TYPE - EXAMINATION</b>		<b>Certificate N°</b>
<b>In accordance with Module B of Directive 2014/90/EU on Marine Equipment</b>		<b>14/SP/3384-2-REV 0</b>
<b>Manufacturer</b>	Name	<b>Industrias AUCA S.L.</b>
	Address	<b>Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN</b>
<p><b>Concerned Equipment:</b> Item n° MED/3.2 : Portable Stored Pressure Fire Extinguisher</p> <p><b>Type :</b> PPE-6 &amp; PPE-9</p> <p><b>Nominal charge:</b> 6 L. &amp; 9 L. water &amp; additive</p> <p><b>Fire ratings:</b> 27A / 233B / 75F &amp; 34A / 233B / 75F</p> <p><b>Temperature range:</b> +5°C / +60°C</p> <p><b>EN3-7 Test report :</b> APRAGAZ n° EN 11280 &amp; EN 11281</p>		
<p>The manufacturer is allowed to affix the marine CE mark  followed by the notified body identification n° to the approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in Module D are fully complied with.</p> <p style="text-align: center;"><b>The approval is valid until 04/05/2024</b></p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3 standard and the Marine Equipment Directive 2014/90/EU as amended on basis of the documentation and samples supplied for review and approval.</p>		
Date : 02/12/2019	Name : B. NEVE	Positiior <b>General Manager</b>
Notified body identification number :	<b>0029</b>	Signature 
Notified body stamp :	<b>APRAGAZ</b> Belgium <b>Inspecting Authority</b>	
Notified body reference :	<b>4567 P 000</b>	