





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE - EXAMINATION		Certificate N° 03/SP/667-2-REV 0
In accordance with module B of Directive 2014/90/EU on Marine Equipment		
Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia)
Concerned Equipment : Wheeled Fire extinguishers with gas cartridge for propellant		
Type : PK50 M1 according to Technical PED Dossier ref. : TIPO 2 Ed/Rev 07/00 dated 01/06/2018 and EN 1866 approval test dossier n° EN 9759 dated 2003/07/30		
Capacity : 50 kg Powder ABC		
Set pressure : max. 17 bar (50°C)		
Test pressure : 25 bar		
Service temperature range : min. -30°C / max. +50°C		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by Nobo n° 0029 and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 25/09/2023.</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU , certifies that the types of these extinguishers conforms with the relevant requirements of the pertinent EN 1866 standards, and the Marine Equipment Directive 2014/90/EU as amended on the base of the information and vessels supplied.</p>		
Date of first issue : 25/09/2003	Name : Ch. Leplat	Position General Manager
Date of actual issue : 05/11/2018		
Notified body identification number :	0029	Signature
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	0105/P4575/MED01	