





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



EC TYPE - EXAMINATION In accordance with module B of Directive 2014/90/EU on Marine Equipment		Certificate N° 15/SP/3718-1-REV 0
Manufacturer	Name	Industrias AUCA S.L.
	Address	Pol. Ind. Alqueria de Mina Calle Tappissers, 3 SP - 46200 Paiporta (Valencia) SPAIN
<p>Concerned Equipment: Item n° MED/3.52 : Wheeled Stored Pressure Fire Extinguisher</p> <p>Type: PPE135A</p> <p>Nominal charge: 135 l water + 1 % AFFF (Aquafilm EX-1)</p> <p>Fire ratings: A – IV B</p> <p>Temperature range: min. +5°C / max. +60°C</p> <p>EN1866-1 Test report : APRAGAZ n° EN 11567</p> <p>Applicable Standard: EN 1866-1:2007</p>		
<p>The manufacturer is allowed to affix the marine CE mark  followed by the notified body number and the year of manufacturing, to the approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in Module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 02/08/2025</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN1866 standards and the Marine Equipment Directive 2014/90/EU as amended on basis of the documentation and samples supplied for review and approval.</p>		
Date : 06/07/2020	Name : B.NEVE	Position General Manager
Notified body identification number :	0029	Signature 
Notified body :	APRAGAZ VZW / ASBL	
Notified body reference :	4567P000	